

## CERTIFICATE OF TYPE TESTING IN ACCORDANCE WITH BS EN 14175

CERTIFICATE & REPORT NO: INV/EN14175/422

DATE: 17th July 2008



**Fume Cupboard Manufacturer:**  
**Chemical Systems Control Ltd**  
**116 Ashbourne Industrial Estate**  
**Ashbourne, Co Meath**  
**IRELAND**

**Fume Cupboard Type:**  
**ChemFlow - 1.5m wide bench-type**  
**Test opening width: 1180mm**  
**Test opening height: 500mm**  
**Extract volume flow rate: 0.330m<sup>3</sup>/s**  
**Average face velocity: 0.509m/s**

This is to certify that the fume cupboard described above has been type-tested in accordance with Part 3, in compliance with the requirements of Part 2 and with reference to Part 1 of BS EN 14175 and resulted in the performance characteristics given in the corresponding test report.

**Tested and Certified by:** Dr A F Bicen  
Invent UK Ltd, 85 Southdown Road, Harpenden, Herts AL5 1PR  
Tel: 01582 461666 : Fax: 01582 460077 : E-mail: info@invent-uk.com

A handwritten signature in blue ink that reads 'A.F. Bicen'. The signature is written in a cursive style with a large loop at the end.